



**Lisa Quiroga**  
PURCHASING COORDINATOR  
[equiroga@turlock.ca.us](mailto:equiroga@turlock.ca.us)

ADMINISTRATIVE SERVICES  
PURCHASING DIVISION

---

156 S. BROADWAY, SUITE 270 | TURLOCK, CALIFORNIA 95380 | PHONE 209-668-5402 | FAX 209-668-5695

REQUEST FOR PROPOSAL

BID NO. 18-054

FOR

GAC PURCHASE AND INSTALLATION AT WELL 8

INFORMATIONAL ADDENDUM NO. 2

DATED ISSUED: December 12, 2018

- 1. Would it be okay to bid re-agglomerated bituminous coal based GAC as an alternative to coconut shell?**  
At this time we are choosing to stick with coconut based carbon that is called out in the RFP.
- 2. On the loading of the 40,000 pounds, can both filters be loaded on the same day or will one at a time with a day or so before between loading each filter?**  
Same day loading.

Administrative Services Purchasing Division, City Hall  
156 S. Broadway, Suite 270  
Turlock, CA 95380-5454  
(209) 668-5402 • Fax (209) 668-5695  
Email: [equiroga@turlock.ca.us](mailto:equiroga@turlock.ca.us)